



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

June 8, 2016

DEPT. OF SAFETY & PROFESSIONAL SERVICES
INDUSTRY SERVICES
THOMAS BRAUN - SECTION CHIEF
1400 E WASHINGTON AVE
MADISON WI 53703

Re: Description: ALTERNATE PRODUCT REVIEW
Manufacturer: DEPT. OF SAFETY & PROFESSIONAL SERVICES
Product Name: (trans id) MINIMUM SHOWER WASTE OUTLET DIAMETER
Model Number(s): NONE
Product File No: 20160173

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.20 (5) (L) 2. based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2021.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This approval permits a minimum of 1.5-inch diameter p-trap when installing a residential replacement shower in place of an existing bathtub.
- The shower shall have no more than one control valve and one shower head.
- The shower head shall have a maximum flow rate of 2.5 gallons per minute (gpm).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail